

Safety Recommendation (TSIB RA-2017-011)

The International Civil Aviation Organization consider amending paragraph 9.2.3 of Annex 14 Volume 1 as follows: The level of protection provided at an aerodrome for rescue and firefighting shall be appropriate to the aerodrome category determined using the principles in 9.2.5 and 9.2.6, except that, where the number of movements of the aeroplanes in the highest category normally using the aerodrome is less than 700 in the busiest consecutive three months, the level of protection provided shall be not ~~less~~ lower than one category below the determined category.